

### 15.20.150: ELECTRIC SERVICE SCHEDULE 1; RESIDENTIAL SERVICE:

A. Applicability: This schedule is applicable to domestic lighting, heating, cooking and other single-phase domestic power use of single-family detached dwelling units and nonsingle-family multiple units separately metered by the utility.

B. Rates: Monthly billings shall equal the sum of the following charges:

	Effective Date		
	Aug. 1, 2023	Aug. 1, 2024	Aug. 1, 2025
	Effective Date		
	Aug. 1, 2023	Aug. 1, 2024	Aug. 1, 2025
Customer charge:			
Per meter, per billing period	\$6.00	\$8.00	\$10.00
Energy charge:			
Peak season (April through September, inclusive):			
First 600 kWh, per kWh	\$0.0952	\$0.1048	\$0.1164
All extra kWh, per kWh	\$0.1050	\$0.1151	\$0.1267
Off peak season (October through March, inclusive):			
All kWh, per kWh	\$0.0952	\$0.1048	\$0.1164

C. Minimum Charge: The minimum charge for service under this schedule shall be the customer charge.

D. Supply Cost Adjustment: All monthly bills shall be adjusted in accordance with electric service schedule 30.

E. Special Conditions:

1. Single-phase residential service at one hundred twenty (120) volts or one hundred twenty/two hundred forty (120/240) volts will be served under this schedule.

2. Single-phase motors used for residential purposes of not more than seven and one-half (7  $\frac{1}{2}$ ) horsepower and energized at one hundred twenty (120) volts or one hundred twenty/two hundred forty (120/240) volts may be served under this schedule.

3. 3-phase residential service will not be offered under this schedule except to those residential customers who have existing 3-phase residential service on the effective date of this schedule.

4. Sale for resale shall not be allowed under this schedule.

5. All new all electric residential services (single-family detached or nonsingle-family detached) that apply for electric service after February 1, 1986, shall be billed under this rate schedule.

6. The maximum main breaker size allowed under this schedule will be three hundred twenty (320) amperes. No instrument metering will be allowed on this schedule. If the main breaker size for any residence as defined above is greater than three hundred twenty (320) amperes and instrument metering is required, schedule 3 will apply. (Ord. 23-12: Ord. 16-17)